

Facility Name: \_\_\_\_\_

Pool/Spa Location: \_\_\_\_\_ Permit # \_\_\_\_\_

Pool/Spa Operator: \_\_\_\_\_

Type of disinfectant:

Chlorine Tablets (circle one)  
     ◆stabilized    ◆non-stabilized

Bromine

Chlorine Liquid

Other

Date	DISINFECTANT RESIDUAL MINIMUM AND MAXIMUM* LEVELS OF DISINFECTANT			TEST DAILY				TEST WEEKLY		RECORD WHEN APPLIED	
	Chlorine	Swimming Pool Minimum (ppm)	Spa/Wading Pool Minimum (ppm)	Combined Chlorine (ppm)  total – free = combined chlorine (<50% of free)	pH  (7.2-8.0)	Temp  max 104°F	Flow  rate (gpm)	Alkalinity  (suggest range of 80 – 200 ppm)	Cyanuric Acid  (if used, max. 90 ppm)	Chemicals Added  (list correct measurement eg: lbs, gal, oz, tbl)	Miscellaneous  problems, closures, remarks, backwash of filter, clarity, injury, etc.
		Chlorine with	2.0								
	Bromine	2.5	4.0								
*Maximum disinfectant allowed 10 ppm											
Time/Level	Time/Level	Time/Level									
1.											
2.											
3.											
4.											
5.											
6.											
7.											
8.											
9.											
10.											
11.											
12.											
13.											
14.											
15.											
16.											
17.											
18.											
19.											
20.											
21.											
22.											
23.											
24.											
25.											
26.											
27.											
28.											
29.											
30.											
31.											

**EMERGENCY PHONE** tested on: \_\_\_\_\_

**SHUT OFF SWITCHES / ALARMS** tested on: \_\_\_\_\_